GEOLOGICAL SURVEY NO.

MICHIGAN DEPARTMENT OF PUBLIC HEALTH
WATER WELL AND PUMP RECORD

PERMIT NUMBER

1 LOCATION OF WELL

County	Township Name	Fraction	Section Number	Town Number	Range Number
Livingston	Brighton	NW ¼ SW ¼ SW ¼	36	1 N/S	6 E

Distance And Direction From Road Intersection: 13000 High Ridge Dr Brighton Mi 48116

Street Address & City of Well Location

Locate with "X" in Section Below



3 OWNER OF WELL: Huron Clinton Metro Ath

Address: 3050 Penobscot Bld Detroit Mi 4822

Address Same As Well Location? ☐ Yes ☒ No

4 WELL DEPTH: (completed) 158 ft. Date of Completion 3-12-86

5 ☐ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Auger ☐ Jetted ☐

6 USE: ☒ Domestic ☐ Type I Public ☐ Type III Public ☐ Irrigation ☐ Type IIa Public ☐ Heat pump ☐ Test Well ☐ Type IIb Public ☐

7 CASING: Diameter ☐ Steel ☐ Threaded ☒ Plastic ☐ Welded

5 in. to 158 ft. depth

in. to ft. depth

Grouted Drill Hole Diameter 8 in. to 144 ft. depth

in. to ft. depth

Height: Above/Below Surface 1 ft. Weight SDR 21 lbs/ft.

Drive Shoe ☐ Yes ☒ No

2 FORMATION DESCRIPTION

FORMATION DESCRIPTION	THICKNESS OF STRATUM	DEPTH TO BOTTOM OF STRATUM
Brown Clay	4	4
Gray Clay	6	10
Gravel	24	34
Gray Clay	7	41
Gravel	4	45
Gray Clay	99	144
Gravely Gray Clay	4	148
Gravel - Med	10	158

USE A 2ND SHEET IF NEEDED

8 SCREEN: ☐ Not installed

Type STAIN WW Diameter 4" Nom

Slot/Gauze 20-18 Length 8

Set between 150 ft. and 158 ft.

FITTINGS: ☒ K-Packer ☐ Lead Packer ☐ Bremer Check

☒ Blank above screen 1 ft. Other

9 STATIC WATER LEVEL: 37 ft. below land surface ☐ Flow

10 PUMPING LEVEL: below land surface

53 ft. after 4 hrs. pumping at 73 G.P.M.

ft. after hrs. pumping at G.P.M.

11 WELL HEAD COMPLETION: ☒ Pitless adapter ☐ 12" above grade ☐ Basement offset ☐ Approved pit

12 WELL GROUTED? ☐ No ☒ Yes From 0 to 144 ft

☐ Neat cement ☒ Bentonite ☒ Other Cuttings

No. of bags of cement Additives

13 Nearest source of possible contamination

Type Septic Distance 200 ft. Direction W

Well disinfected upon completion? ☒ Yes ☐ No

14 PUMP: ☐ Not installed ☐ Pump Installation Only

Manufacturer's name Red Jacket

Model number 10EC HP 5 Volts 220

Length of Drop Pipe 80 ft. capacity 73 G.P.M.

TYPE: ☒ Submersible ☐ Jet

PRESSURE TANK:

Manufacturer's name AmTrol

Model number Capacity 100 Gallons

15. Remarks, elevation, source of data, etc.

16. WATER WELL CONTRACTOR'S CERTIFICATION:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Cribley Drilling Co Inc 81-05

REGISTERED BUSINESS NAME REGISTRATION NO.

Address Dexter Mi 48130

Signed Jack G. Clark Date 4-18-86

AUTHORIZED REPRESENTATIVE

D57d 2/84

Authority: Act 368 PA 1978
Completion: Required
Penalty: Conviction of a violation of any provision in a

LOCAL HEALTH DEPT COPY